

MOUNT LAUREL FIRE DEPARTMENT

Est. 1953

69 Elbo Lane
Mount Laurel, NJ 08054

Tel: (856) 234-6053
Fax: (856) 234-3756

EMERGENCY AND EXIT LIGHTING LOG 30 SECONDS PER MONTH / 1 HOUR PER YEAR

THIS DOCUMENT SHALL BE SECURELY ATTACHED TO THE WALL IN CLOSE PROXIMITY TO THE MAIN ELECTRICAL CIRCUIT BREAKER PANEL.

	Exit Signs Operational	Emergency Lights Operational	Tested By	Explain "No" & date repaired
JANUARY	_____	_____	_____	_____
FEBRUARY	_____	_____	_____	_____
MARCH	_____	_____	_____	_____
APRIL	_____	_____	_____	_____
MAY	_____	_____	_____	_____
JUNE	_____	_____	_____	_____
JULY	_____	_____	_____	_____
AUGUST	_____	_____	_____	_____
SEPTEMBER	_____	_____	_____	_____
OCTOBER	_____	_____	_____	_____
NOVEMBER	_____	_____	_____	_____
DECEMBER	_____	_____	_____	_____

THE ONE (1) HOUR ANNUAL TESTING OF THE EMERGENCY LIGHTING SYSTEM WAS CONDUCTED ON _____ AND FOUND OPERATIONAL. DEFICIENCIES NOTED ARE _____ CORRECTED ON _____.